Arbitary Pole-Placement in the LQ Control Paradigm

L. Keviczky, J. Bokor

Széchenyi István University, Győr Computer and Automation Research Institute and Control Engineering Research Group Hungarian Academy of Sciences H-1111 Budapest, Kende u 13-17, Hungary Phone: +361-466-5435 e-mail: keviczky@sztaki.hu; bokor@sztaki.hu

Abstract: The specific relationships between the classical pole-placement state feedback, the Riccati equation based LQ paradigm and the Kalman frequency domain approach are discussed. It is shown that arbitrary pole placement is not possible by standard LQ optimality. A possible solution of this anomaly is to use more general LQ criterion with specific weights on the state, input and crossterm.

Keywords: LQ problem, Kalman equation, optimality

1. Introduction

In the early time of control theory the optimization of transient processes in dynamic systems used a quadratic criterion, i.e., the integral square of error

$$I_2 = \int_0^\infty e^2(t) dt = \int_{-\infty}^\infty E(-s) E(s) ds = \frac{1}{\pi} \int_0^\infty \left| E(j\omega) \right|^2 d\omega.$$
(1)

Here e(t) is the error signal of a closed-loop control system. The second half of (1) is the so-called Parseval theorem [3], [6], using the strictly proper E(s), the Laplace transform of e(t).

This integral criterion was very popular, because the evaluation of (1) could be performed analytically and easily computed even by the early slow computers (by preprogrammed formulas). The general theory was called Wiener approach [3] and thousands of papers were published for the different optimal designs. The first critics came from the industry: the optimal regulators minimizing (1) were not acceptable in the practice, because they resulted a very large (20~25 %) overshoot in the step response transients.

One way to overcome this problem was first to introduce a more general quadratic integral criterion, penalizing the different state variables as

$$I_{2(n)} = \int_0^\infty \left[x^2 + \tau_1^2 \dot{x}^2 + \dots + \tau_n^2 (x^{(n)})^2 \right] \mathrm{d}t \tag{2}$$

Vol. 6. No. 5. 2013

which is called generalized quadratic criterion. It is not difficult to show that (2) has an equivalent form

$$I_{2(n)} = \int_0^\infty \left[x^2 + \alpha \dot{x} + \dots + \alpha_n x^{(n)} \right]^2 \mathrm{d}t$$
(3)

where $x(\infty) = \dot{x}(\infty) = \cdots = x^{(n-1)}(\infty) = 0$ and $c_0 = \alpha_1 x_0^2$, $x_0 = x(0)$. The coefficients of the two forms depend on each other by the Rekasius-Feldbaum equations [1], [2]

$$\tau_1^2 = \alpha_1^2 - 2\alpha_0\alpha_2$$

$$\tau_2^2 = \alpha_2^2 - 2\alpha_1\alpha_3 + 2\alpha_0\alpha_4$$

$$\tau_3^2 = \alpha_3^2 - 2\alpha_2\alpha_4 + 2\alpha_1\alpha_3 - 2\alpha_0\alpha_4$$

:

$$\tau_n^2 = \alpha_n^2$$
(4)

From (3) the minimum can be easily seen, if x(t) fulfils the differential equation

$$\alpha_n x^{(n)} + \alpha_{n-1} x^{(n-1)} + \dots + \alpha_1 x + \alpha_0 = 0; \ \alpha_0 = 1.$$
(5)

Here the signal x(t) is more general than e(t), because it can be one of the state variables of a linear system.

2. State feedback (SFB)

Consider a SISO continuous time linear time invariant (LTI) dynamic plant described by the state variable representation (SVR)

$$\frac{\mathrm{d}x}{\mathrm{d}t} = \dot{x} = Ax + bu$$

$$y = c^{\mathrm{T}}x$$
(6)

Here u, y and x are the input, output and state variables of the controlled process and T stands for transposition. The transfer function representation (*TFR*) of the openloop system can be calculated by

$$P(s) = \frac{\mathbf{B}(s)}{\mathbf{A}(s)} = \mathbf{c}^{\mathrm{T}} (s \mathbf{I} - \mathbf{A})^{-1} \mathbf{b} = \mathbf{c}^{\mathrm{T}} \mathbf{\Phi}(s) \mathbf{b}$$
(7)

where I is the unit matrix,

$$\Phi(s) = (sI - A)^{-1} = L \{e^{At}\} = \frac{\Psi(s)}{A(s)}$$
$$\Psi(s) = \operatorname{adj}(sI - A)$$
(8)

and

$$B(s) = s^{n} + b_{1}s^{n-1} + \dots + b_{n-1}s + b_{n} = \boldsymbol{c}^{\mathrm{T}}\boldsymbol{\Psi}(s)\boldsymbol{b}$$
(9)

$$A(s) = s^{n} + a_{1}s^{n-1} + \dots + a_{n-1}s + a_{n} = \det(sI - A)$$
(10)

are the numerator and denominator polynomials, respectively. If the feedback is restricted to a linear *SFB*, then the classical solution can be written as

$$u = k_{\rm r} \, r - \boldsymbol{k}^{\rm T} \, \boldsymbol{x} \tag{11}$$

where r is the reference signal, k_r is a calibrating constant and k^T is the linear *SFB* vector. It is easy to check that the transfer function from the reference signal r to the output y is [4]

$$T_{\rm ry}(s) = \boldsymbol{c}^{\rm T} \left(s \boldsymbol{I} - \boldsymbol{A} + \boldsymbol{b} \boldsymbol{k}^{\rm T} \right)^{-1} \boldsymbol{b} \, \boldsymbol{k}_{\rm r} = \frac{\boldsymbol{k}_{\rm r} \, {\rm B}(s)}{{\rm A}(s) + \boldsymbol{k}^{\rm T} \boldsymbol{\Psi}(s) \boldsymbol{b}}$$
(12)

where $k_{\rm r}$ is obtained by requiring that the static gain of $T_{\rm rv}$ should be equal to one

$$k_{\rm r} = \frac{\boldsymbol{k}^{\rm T} \boldsymbol{A}^{-1} \boldsymbol{b} - 1}{\boldsymbol{c}^{\rm T} \boldsymbol{A}^{-1} \boldsymbol{b}}$$
(13)

The usual classical design goal is to determine the feedback gain k^{T} so that the closed-loop system has the characteristic polynomial

$$R(s) = s^{n} + r_{1}s^{n-1} + \dots + r_{n-1}s + r_{n}$$
(14)

The solution formally means equating the characteristic polynomial of the closed-loop with the desired polynomial ("pole placement method")

$$\mathbf{R}(s) = \det\left(s\mathbf{I} - \mathbf{A} + b\mathbf{k}^{T}\right) = \mathbf{A}(s) + \mathbf{k}^{T} \Psi(s)\mathbf{b} = \mathbf{A}(s) + \mathbf{K}(s)$$
(15)

to compute k^{T} . The solution always exists if P(s) is controllable.

If the *TFR* of the process is known then one can easily form a controllable canonical form $\{A_c, b_c, c_c^T\}$ with

$$\boldsymbol{A}_{c} = \begin{bmatrix} -\boldsymbol{a}_{c}^{\mathrm{T}} \\ \boldsymbol{I}, \boldsymbol{0} \end{bmatrix} \boldsymbol{a}_{c} = [\boldsymbol{a}_{1}, \boldsymbol{a}_{2}, \cdots, \boldsymbol{a}_{n}]^{\mathrm{T}} \boldsymbol{b}_{c} = [1, 0, \cdots, 0]^{\mathrm{T}} \boldsymbol{c}_{c} = [\boldsymbol{c}_{1}, \boldsymbol{c}_{2}, \cdots, \boldsymbol{c}_{n}]^{\mathrm{T}}$$
(16)

and now the feedback gain is obtained from (15) as

$$\boldsymbol{k}_{c}^{\mathrm{T}} = [r_{1} - a_{1}, r_{2} - a_{2}, \cdots, r_{n} - a_{n}] = [k_{1}, k_{2}, \cdots, k_{n}]$$
(17)

because

$$\boldsymbol{\Psi}_{c}(s)\boldsymbol{b}_{c} = [s^{n-1}, \cdots, s, 1]^{\mathrm{T}}$$
(18)

and

$$\boldsymbol{k}_{c}^{\mathrm{T}} \boldsymbol{\Psi}_{c}(s) \boldsymbol{b}_{c} = k_{1} s^{n-1} + \cdots + k_{n-1} s + k_{n} = K(s).$$
(19)

The calibration factor is calculated by

$$k_{\rm r} = \frac{a_n + (r_n - a_n)}{b_n} = \frac{a_n}{b_n}$$
(20)

The SVR of the closed-loop system is described by

$$\frac{\mathrm{d}\boldsymbol{x}}{\mathrm{d}t} = \left(\boldsymbol{A} - \boldsymbol{b}\,\boldsymbol{k}^{\mathrm{T}}\right)\boldsymbol{x} + k_{\mathrm{r}}\,\boldsymbol{b}\,\boldsymbol{r} = \bar{\boldsymbol{A}} + k_{\mathrm{r}}\,\boldsymbol{b}\,\boldsymbol{r}$$
$$\boldsymbol{y} = \boldsymbol{c}^{\mathrm{T}}\boldsymbol{x}$$
(21)

It is easy to see from equation (12) that $T_{rv}(s)$ is now

$$T_{\rm ry}(s) = \frac{k_{\rm r} \,\mathrm{B}(s)}{\mathrm{R}(s)}$$
(22)

i.e., besides reaching the desired pole-placement the SFB leaves the open-loop zeros untouched.

3. The LQR (Linear system - Quadratic criterion - Regulator) problem

Not only the bad transient of the error signal obtained from the optimal quadratic criterion was the problem, but also the big amplitude jumps necessary to the control action. An other way suggested to overcome the combined problem was the introduction of a penalty for the energy of the control signal. This optimization was formulated by the more general [3], [4] quadratic criterion

$$I = \frac{1}{2} \int_{0}^{\infty} \left[\mathbf{x}^{\mathrm{T}}(t) \mathbf{W}_{\mathrm{x}} \mathbf{x}(t) + w_{\mathrm{u}} u^{2}(t) \right] \mathrm{d}t$$
⁽²³⁾

where $\mathbf{x}(t)$ is the state vector, u(t) is the input of the process, respectively. The positive definite W_x stands for penalizing the variations in the state space, w_u is for penalizing the energy of the control action, which is more general than (2). The solution, minimizing (23) is again a negative *SFB* [7]

$$u(t) = -\boldsymbol{k}_{LQ}^{T} \boldsymbol{x}(t)$$
⁽²⁴⁾

where \boldsymbol{k}_{LO}^{T} is given by

$$\boldsymbol{k}_{\mathrm{LQ}}^{\mathrm{T}} = \frac{1}{w_{\mathrm{u}}} \boldsymbol{b}^{\mathrm{T}} \boldsymbol{P}$$
⁽²⁵⁾

where the symmetric positive semi definite matrix P can be obtained from the solution of the algebraic Riccati equation [4]

$$\boldsymbol{P}\boldsymbol{A} + \boldsymbol{A}^{\mathrm{T}}\boldsymbol{P} - \frac{1}{w_{\mathrm{u}}}\boldsymbol{P}\boldsymbol{b}\boldsymbol{b}^{\mathrm{T}}\boldsymbol{P} = -\boldsymbol{W}_{\mathrm{x}}$$
(26)

Analytic solution is not possible, because this equation is nonlinear in P, therefore only numeric solution can be obtained by MATLAB[©] and other *CACSD* programs.

Introducing the orthogonal factorization

$$\boldsymbol{W}_{\mathrm{x}} = \boldsymbol{G}^{\mathrm{T}}\boldsymbol{G} \tag{27}$$

the closed-loop system is stable if the auxiliary process

$$\boldsymbol{v} = \boldsymbol{G}\boldsymbol{x} \tag{28}$$

is observable.

The characteristic polynomial coefficients are computed now from

$$[r_1, r_2, \cdots, r_n]^{\mathrm{T}} = \boldsymbol{k}_{\mathrm{LQ}}^{\mathrm{T}} + [a_1, a_2, \cdots, a_n]^{\mathrm{T}}$$
(29)

Note that this SFB also provides the same $T_{rv}(s)$ as (22) before.

A joint use of time domain optimality criteria, prescribed constraints and pole locations are often required in practice. Optimal and partially optimal pole placement based on optimality criteria (58) was studied in [19], [20], [21] and [22]. It can be shown, however, that [20] does not provide solution for the general problem (illustrated by the examples later), mainly due to the fact that it uses only the weights W_x , W_u but not the cross term W_{ux} .

4. The frequency domain solution of the LQR problem

The LQR approach is widely used for control problems in all over the world, however, in a practical problem it is not an easy task to find the best W_x and w_u weights, which are usually obtained by trial and error iterative methods. The LQR problem has an almost forgotten frequency domain solution, too, which will give us a deterministic design process to find useful relationships between the classical pole placement SFB solution and the LQR paradigm. It can be shown that the simpler dyadic factorization [3]

$$\boldsymbol{W}_{\boldsymbol{x}} = \boldsymbol{g}\boldsymbol{g}^{\mathrm{T}} \quad \boldsymbol{g} = [g_1, \cdots, g_{n-1}, g_n]^{\mathrm{T}}$$
(30)

can also be used. The frequency domain condition of the minimum of (23) is called the Kalman equation [3] or sometimes it is named frequency domain identity (FDI)

$$w_{\rm u} \left| 1 + \boldsymbol{k}^{\rm T} \boldsymbol{\Phi}(s) \boldsymbol{b} \right|^2 = w_{\rm u} + \left| \boldsymbol{g}^{\rm T} \boldsymbol{\Phi}(s) \boldsymbol{b} \right|^2$$
(31)

Assuming unity weight $w_{\rm u} \equiv 1$ the equation becomes even simpler

$$\left|1+\boldsymbol{k}^{\mathrm{T}}\boldsymbol{\Phi}(s)\boldsymbol{b}\right|^{2}=1+\left\|\boldsymbol{g}^{\mathrm{T}}\boldsymbol{\Phi}(s)\boldsymbol{b}\right\|_{2}^{2}=1+\left|\boldsymbol{g}^{\mathrm{T}}\boldsymbol{\Phi}(s)\boldsymbol{b}\right|^{2}$$
(32)

Using the well known relationship of complex functions

$$\{Z(s)\}^{2} = |Z(s)|^{2} = Z(s)Z(-s)$$
(33)

and introducing the (n-1)-th order polynomial G(s) as the numerator of

$$H(s) = \boldsymbol{g}^{\mathrm{T}} \boldsymbol{\Phi}(s) \boldsymbol{b} = \frac{\boldsymbol{g}_{0}(s)}{\boldsymbol{A}(s)} = \frac{\boldsymbol{g}_{1}(s)^{n-1} + \dots + \boldsymbol{g}_{n-1}(s) + \boldsymbol{g}_{n}}{\boldsymbol{A}(s)}$$
(34)

25

the equation (32) can be rearranged into a new form

$$\underbrace{[A(s) + \mathbf{k}^{\mathrm{T}} \Psi(s)\mathbf{b}]}_{R(s)} \underbrace{[A(-s) + \mathbf{k}^{\mathrm{T}} \Psi(-s)\mathbf{b}]}_{R(-s)} = A(s)A(-s) + \underbrace{[\mathbf{g}^{\mathrm{T}} \Psi(s)\mathbf{b}]}_{G(s)} \underbrace{[\mathbf{g}^{\mathrm{T}} \Psi(-s)\mathbf{b}]}_{G(-s)}$$
(35)

which provides the quadratic polynomial solution of the Kalman equation. Thus the final quadratic equation, ensuring relationship between the process A(s), design R(s) and weighting G(s) polynomials, is

$$R(s)R(-s) = A(s)A(-s) + G(s)G(-s) \qquad |R(s)|^{2} = |A(s)|^{2} + |G(s)|^{2}$$
(36)

or in the general form

$$w_{\rm u} |{\rm R}(s)|^2 = w_{\rm u} |{\rm A}(s)|^2 + |{\rm G}(s)|^2$$
 (37)

Observe that the solution tends to $\mathbf{R}(s) = \mathbf{A}(s)$ if $W_u \to \infty$ and $\mathbf{g}^T \mathbf{x} = 0$ if $w_u \to 0$. Do not forget that $\mathbf{K}(s)$ and $\mathbf{G}(s)$ are of (n-1)-th order [8].

5. Some anomalies in the LQR problem

The solution of the polynomial equation can be a direct coefficient comparison or a spectral factorization approach [5]. Consider some examples in the sequel.

Example 1

Consider a first order example with

$$A(s) = s + a_1$$
 $R(s) = s + r_1$ $G(s) = g_1$ (38)

The two sides of (35) are

$$s^{2} - r_{1}s + r_{1}s + r_{1}^{2} = -s^{2} - a_{1}s + a_{1}s + a_{1}^{2} + g_{1}^{2}$$
(39)

and the solution is

$$r_1^2 = a_1^2 + g_1^2 > 0 (40)$$

and

$$k_1 = r_1 - a_1 = \sqrt{a_1^2 + g_1^2} - a_1 > 0 \tag{41}$$

If we want to ensure (place) a required pole then the necessary weight in the LQR problem is

$$g_1 = \sqrt{r_1^2 - a_1^2} \tag{42}$$

It is easy to see that only such r_1 can be placed, which fulfills the condition

$$r_1^2 > a_1^2 \Rightarrow |r_1| > |a_1| \Rightarrow r_1 > |a_1| \tag{43}$$

for stable design polynomial R(s). So this example shows that only a faster pole can be placed by the LQR optimization comparing to the original process pole.

Example 2

Consider a second order example with

$$A(s) = s^{2} + a_{1}s + a_{2} \qquad R(s) = s^{2} + r_{1}s + r_{2} \qquad G(s) = g_{1}s + g_{2}$$
(44)

The two sides of (35) are now

$$(s^{2} + r_{1}s + r_{2})(s^{2} - r_{1}s + r_{2}) = (s^{2} + a_{1}s + a_{2})(s^{2} - a_{1}s + a_{2}) + (g_{1}s + g_{2})(-g_{1}s + g_{2})$$
(45)

and the solutions are

$$r_2 = \sqrt{a_2^2 + g_2^2} > a_2 \tag{46}$$

$$r_{1} = \sqrt{2\left(\sqrt{a_{2}^{2} + g_{2}^{2}} - a_{2}\right)} + \left(a_{1}^{2} + g_{1}^{2}\right) = \sqrt{2\left(r_{2} - a_{2}\right)} + \left(a_{1}^{2} + g_{1}^{2}\right) > a_{1} > 0$$

$$(47)$$

The SFB to be applied is given by

$$k_1 = r_1 - a_1 > 0 \qquad k_2 = r_2 - a_2 > 0 \tag{48}$$

For pole placement the necessary LQR weights are

$$g_2 = \sqrt{r_2^2 - a_2^2} \tag{49}$$

and

$$g_1 = \sqrt{r_2^2 - a_1^2 - 2(r_2 - a_2)} = \sqrt{2(\mu_r^2 - \mu_a^2)}$$
(50)

where

$$\mu_{\rm r}^2 = \frac{r_{\rm l}^2 - 2r_2}{2} = \frac{\left(s_{\rm l}^{\rm r}\right)^2 + \left(s_{\rm 2}^{\rm r}\right)^2}{2} \tag{51}$$

and

$$\mu_{a}^{2} = \frac{a_{1}^{2} - 2a_{2}}{2} = \frac{\left(s_{1}^{a}\right)^{2} + \left(s_{2}^{a}\right)^{2}}{2}$$
(52)

It is easy to see that there are such $\{r_1, r_2\}$ domains, which can not be reached by any $\{g_1, g_2\}$ selection. These conditions are

$$r_2^2 > a_2^2 \Longrightarrow |r_2| > |a_2| \Longrightarrow r_2 > |a_2| \tag{53}$$

27





These conditions are graphically demonstrated on Fig.1, where the shaded area shows the unreachable design parameters for the case of open-loop process parameters $|a_2| = 0.8$ and $2\mu_a^2 = 0.5$.

One can check these results either via the solution of the Riccati equation (very time consuming method) or by the spectral factorization approach

$$R(s)R(-s) = [A(s)A(-s) + G(-s)G(s)]^{+} [A(s)A(-s) + G(-s)G(s)]^{-}$$
(55)

as the solution of (36), i.e., by

$$R(s) = \left[A(s)A(-s) + G(s)G(-s)\right]^{+}$$
(56)

6. Solutions for LQ-pole placement

We can not explain the above anomalies physically and provide unique solutions, however, offer some applicable solutions. Therefore it is necessary to discuss first the original *MIMO LQR* problem.

Infinite-horizon, continuous-time LQ Regulator (LQR)

For a continuous-time MIMO linear system described by

$$\frac{\mathrm{d}x}{\mathrm{d}t} = \dot{x} = Ax + Bu$$

$$x(0) = x_0$$
(57)

with a LQ cost functional (performance index) defined as

$$J(\boldsymbol{x}_{0},\boldsymbol{u}) = \frac{1}{2} \int_{0}^{\infty} \left(\boldsymbol{x}^{\mathrm{T}} \boldsymbol{W}_{\mathrm{x}} \boldsymbol{x} + \boldsymbol{u}^{\mathrm{T}} \boldsymbol{W}_{\mathrm{u}} \boldsymbol{u} \right) \mathrm{d}t$$
(58)

with $W_x \ge 0$ and $W_u > 0$, the stabilizing feedback control law that minimizes the value of the cost is

$$\boldsymbol{u} = \boldsymbol{K}\boldsymbol{x} \tag{59}$$

where \boldsymbol{K} is given by

$$\boldsymbol{K} = -\boldsymbol{W}_{\mathrm{u}}^{-1}\boldsymbol{B}^{\mathrm{T}}\boldsymbol{P} \tag{60}$$

and $\boldsymbol{P} = \boldsymbol{P}^{\mathrm{T}} > 0$ is the solution of the continuous time algebraic Riccati equation

$$\boldsymbol{A}^{\mathrm{T}}\boldsymbol{P} + \boldsymbol{P}\boldsymbol{A} - \boldsymbol{P}\boldsymbol{B}\boldsymbol{W}_{\mathrm{u}}^{-1}\boldsymbol{B}^{\mathrm{T}}\boldsymbol{P} + \boldsymbol{W}_{\mathrm{x}} = \boldsymbol{0}$$

$$\tag{61}$$

It is possible to construct an even more general LQR performance index, which penalizes the interaction of the state and control variables, too:

where the stabilizing feedback control law that minimizes the value of the cost is again

u = Kx

but here K is given by

$$\boldsymbol{K} = -\boldsymbol{W}_{\mathrm{u}}^{-1} \left(\boldsymbol{W}_{\mathrm{ux}} + \boldsymbol{B}^{\mathrm{T}} \boldsymbol{P} \right)$$
(63)

and $\mathbf{P} = \mathbf{P}^{T} > 0$ is now the solution of a more complex algebraic Riccati equation

$$\boldsymbol{P}\boldsymbol{A} + \boldsymbol{A}^{\mathrm{T}}\boldsymbol{P} - \left(\boldsymbol{P}\boldsymbol{B} + \boldsymbol{W}_{\mathrm{ux}}^{\mathrm{T}}\right)\boldsymbol{W}_{\mathrm{u}}^{-1}\left(\boldsymbol{W}_{\mathrm{ux}} + \boldsymbol{B}^{\mathrm{T}}\boldsymbol{P}\right) + \boldsymbol{W}_{\mathrm{x}} = \boldsymbol{0}$$

$$\tag{64}$$

These results are standard facts of the *LQR* theory. For the sake of completeness a sketch of the proof for the sufficiency is given as follows: assume that $W_{ux} > 0$, $W_x \ge 0$, W_{ux} are given. Then it will be shown that (62) is minimized by **K** in (60). The Riccati equation can be rewritten as

$$\boldsymbol{P}\boldsymbol{A} + \boldsymbol{A}^{\mathrm{T}}\boldsymbol{P} - \boldsymbol{K}\boldsymbol{W}_{\mathrm{u}}^{-1}\boldsymbol{K} + \boldsymbol{W}_{\mathrm{x}} = \boldsymbol{0}$$
(65)

$$x^{\mathrm{T}}P(\dot{x} - Bu) + (\dot{x} - Bu)^{\mathrm{T}}Px - x^{\mathrm{T}}K^{\mathrm{T}}W_{u}Kx + x^{\mathrm{T}}Wx = 0$$

Using $-W_{u}K = B^{T}P + W_{ux}$ and $\frac{d}{dt}(x^{T}Px) = \dot{x}^{T}Px + x^{T}P\dot{x}$, one arrives at

$$\boldsymbol{x}^{\mathrm{T}}\boldsymbol{W}_{\mathrm{x}}\boldsymbol{x} + 2\boldsymbol{u}^{\mathrm{T}}\boldsymbol{W}_{\mathrm{ux}}\boldsymbol{x} + \boldsymbol{u}^{\mathrm{T}}\boldsymbol{W}_{\mathrm{u}}\boldsymbol{u} = -\frac{\mathrm{d}}{\mathrm{d}t}\left(\boldsymbol{x}^{\mathrm{T}}\boldsymbol{P}\boldsymbol{x}\right) + \left(\boldsymbol{u} - \boldsymbol{K}\boldsymbol{x}\right)^{\mathrm{T}}\boldsymbol{W}_{\mathrm{u}}\left(\boldsymbol{u} - \boldsymbol{K}\boldsymbol{x}\right)$$

and by integration

$$J(\mathbf{x}_0, \mathbf{u}) = \frac{1}{2} \mathbf{x}^{\mathrm{T}}(t_0) \mathbf{P}_{t_0} \mathbf{x}(t_0) + \frac{1}{2} \int_{t_0}^{\infty} (\mathbf{u} - \mathbf{K} \mathbf{x})^{\mathrm{T}} \mathbf{W}_{\mathrm{u}}(\mathbf{u} - \mathbf{K} \mathbf{x}) \,\mathrm{d} t$$

is obtained. Obviously $J_{\min}(\mathbf{x}_0) = \frac{1}{2} \mathbf{x}^{\mathrm{T}}(t_0) \mathbf{P}_{t_0} \mathbf{x}(t_0)$ if $\mathbf{u} = \mathbf{K}\mathbf{x}$.

Inverse optimality for LQR performance

Given a stabilizing feedback $\boldsymbol{u} = \boldsymbol{K}_{\boldsymbol{X}}$ for (57) one can formulate the problem whether there exists an *LQR* problem of the form (58) or (62) that has the given feedback as a solution, i.e., the feedback is optimal. If the pair $(\boldsymbol{A}, \boldsymbol{B})$ is controllable, then for any given spectrum Λ there is a feedback gain \boldsymbol{K}_{Λ} such that $\lambda (\boldsymbol{A} + \boldsymbol{B}\boldsymbol{K}_{\Lambda}) = \Lambda$. Concerning the pole-placement problem one can state that a spectrum Λ is *LQ* optimal if there is an associated \boldsymbol{K}_{Λ} such that it is a solution of the RICCATI equation with a $\boldsymbol{W}_{x} \geq 0$.

It turns out that the problem associated to the performance index (58) is nontrivial while the general case, corresponding to (62) can be always solved.

The MIMO KALMAN-FDI

In frequency domain the solution of the problem leads to the so called return difference condition. Its single input formulation is due to Kalman and was later extended by Anderson and Moore [9].

Specifically, **K** is optimal for $W_x = W_x^T \ge 0$ and $W_u = W_u^T > 0$ if and only if A + BK is stable and there exists an $W_u = W_u^T > 0$ that satisfies the return difference inequality:

$$\left[\boldsymbol{I} + \boldsymbol{H}_{LQ}\left(-s\right)\right]^{T} \boldsymbol{W}_{u}\left[\boldsymbol{I} + \boldsymbol{H}_{LQ}\left(s\right)\right] \ge \boldsymbol{W}_{u}$$
(66)

for all $s = j\omega$, $\omega \in \mathbb{R}$ or equivalently the Kalman-FDI is also satisfied:

$$\left[I + H_{LQ}(-s)\right]^{1} W_{u}\left[I + H_{LQ}(s)\right] = W_{u} + H(-s)H(s)$$
(67)

where

$$H_{LQ}(s) = K(sI - A)^{-1}B \qquad H(s) = G(sI - A)^{-1}B \qquad W_{x} = G^{T}G$$
(68)

Choosing $W_{u} = w_{u}I$, $w_{u} > 0$ one has:

Proposition 1 Consider (58), then the static state feedback gain K is optimal for some $W_x > 0$, $W_u > 0$ if and only if

$$\operatorname{Re}\lambda_{i} \{\boldsymbol{A} + \boldsymbol{B}\boldsymbol{K}\} < 0 \quad \forall \ i$$

$$\sigma_{i} \{\!\!\{ + \boldsymbol{K}(i\omega - \boldsymbol{A})^{-1}\boldsymbol{B} \!\!\} > 1 \quad \forall \ i \quad \forall \ \omega$$

where σ_i denotes the singular values. For SISO systems the Kalman-FDI becomes:

$$w_{\rm u} \Big[1 + H_{\rm LQ} (-s) \Big] \Big[1 + H_{\rm LQ} (s) \Big] = w_{\rm u} + H (-s) H (s)$$
(69)

where $H(s) = \frac{G(s)}{A(s)}$ and

$$H_{LQ}(s) = \mathbf{k}^{\mathrm{T}} (s\mathbf{I} - \mathbf{A})^{-1} \mathbf{b} = \mathbf{k}^{\mathrm{T}} \mathbf{\Phi}(s) \mathbf{b} = \frac{\mathbf{k}^{\mathrm{T}} \mathbf{\Psi}(s) \mathbf{b}}{A(s)}$$

Denoting the closed loop characteristic align by R(s),

$$R(s) = \det(sI - A - bk^{T}) = \det(sI - A)\det[1 + k^{T}(sI - A)^{-1}b]$$

leading to

$$R(s) = A(s) \left[1 + H_{LQ}(s) \right]$$

if $w_u \equiv 1$ is chosen. From the Kalman-FDI one obtains:

$$w_{\mathrm{u}}\frac{\mathrm{R}(s)\mathrm{R}(-s)}{\mathrm{A}(s)\mathrm{A}(-s)} = w_{\mathrm{u}} + \frac{\mathrm{G}(s)\mathrm{G}(-s)}{\mathrm{A}(s)\mathrm{A}(-s)} \qquad \qquad \frac{\mathrm{R}(s)\mathrm{R}(-s)}{\mathrm{A}(s)\mathrm{A}(-s)} = 1 + w_{\mathrm{u}}^{-1}\frac{\mathrm{G}(s)\mathrm{G}(-s)}{\mathrm{A}(s)\mathrm{A}(-s)} \tag{70}$$

which corrresponds to (36). We now give a simple test for a given state feedback gain k to decide if it can be an LQ optimal gain.

Proposition 2 Assume that with $u = \mathbf{k}^T \mathbf{x}$ the closed loop is stable. Then \mathbf{k} is optimal for some $W_x \ge 0$, and $w_u > 0$ if and only if

$$\left|\frac{R(i\omega)}{A(i\omega)}\right| \ge 1 \quad \forall \ \omega \tag{71}$$

Proof. If k is LQ optimal, then the closed loop is stable and from the Kalman-FDI follows that $[1 + H_{LQ}] \ge 1$ and (71) is satisfied. On the contrary, if k is stabilizing and (71) is satisfied, one can find a $W_x \ge 0$ and $w_u > 0$ such that the Kalman-FDI is

satisfied, too, i.e., k is LQ optimal with this W_x and W_u .

Example 3

Let the system be given as

$$\dot{x} = -2x + u$$

i.e., A = A = a = -2, B = B = b = 1. The open loop (plant) transfer function is

$$P(s) = \frac{1}{s+2} = \frac{b_1}{s+a_1} \qquad A(s) = s+a_1$$

Applying state feedback u = kx, allocate the pole to $p_1 = -r_1 = -1$, i.e. $R(s) = s + r_1$. This will be performed by k = 1 and the closed loop system will be

$$\dot{\overline{x}} = -1\overline{x} + u$$

i.e.,

$$R(s) = s + r_1 = s + 1$$

Plotting the Bode diagram for

$$\frac{R(i\omega)}{A(i\omega)} = \frac{1}{2} \frac{|1+i\omega|}{|1+i\omega/2|}$$

one can deduce that this is below the 0 dB for small frequencies and asymptotically approaches 0 dB if $\omega \rightarrow \infty$. This shows that this k cannot be optimal for the LQR performance index (58).

It is seen that using static state feedback, it is not possible to "slow down" the system since $r_1 > a_1$ has to be satisfied for LQ optimality.

Time domain conditions

In time domain inverse optimality of the feedback gain can be described through the concept of passivity.

For a *LTI* system passivity, equivalent in this case to the positive realness, is assured in accordance with the following lemma, often termed as the KALMAN-YACUBOVICH-POPOV lemma:

Lemma 1 A stable system (57) is passive, if and only if, there exists a matrix $P = P^{T} > 0$ such that

$$PA + A^{T}P = -W_{x} \le 0$$
$$PB = C^{T}$$
(72)

with $C \in \mathbb{R}^{m \times n}$ a suitable output matrix for system (61). Then, inverse optimality is given by the following result:

Proposition 3 A stable feedback gain-matrix \mathbf{K} is optimal for a given input weighting matrix $\mathbf{W}_{u} > 0$ and some state weighting matrix $\mathbf{W}_{x} \ge 0$, i.e., it minimizes a performance index of the form of (58), if and only if, the closed-loop system with gain-

matrix

$$\bar{\boldsymbol{K}} = \frac{1}{2} \, \boldsymbol{K} \tag{73}$$

is passive for an output matrix $C = -W_{\mu}K$.

Inverse optimality for LQR performance (67)

Including the cross term W_{ux} in the LQR performance index makes the problem trivial. For a stabilizing state feedback K one can find the extended matrix W (see (75)) such, that K is LQ optimal according to the performance (62). The procedure of deriving such weighting matrices, however, is neither trivial, nor unique. We show one possible solution that follows the procedure in [12].

It is obvious, that for any $W_u > 0$ the stabilizing feedback u = Kx is optimal for the performance index:

$$J(x_0, \boldsymbol{u}) = \frac{1}{2} \int_0^\infty (\boldsymbol{u} - \boldsymbol{K} \boldsymbol{x})^{\mathrm{T}} \boldsymbol{W}_{\mathrm{u}} (\boldsymbol{u} - \boldsymbol{K} \boldsymbol{x}) \,\mathrm{d} t$$
(74)

i.e., $W_x = K^T W_u K \ge 0$ and $W_{ux} = -W_u K$ in (58). Observe that this corresponds to the solution P = 0 of the Riccati equation.

A more standard solution is given by the following result:

Proposition 4 For a given stabilizing feedback K there exists a feedback law u = Kx and an extended matrix

$$\boldsymbol{W} = \begin{bmatrix} \boldsymbol{W}_{\mathrm{x}} & \boldsymbol{W}_{\mathrm{ux}} \\ \boldsymbol{W}_{\mathrm{ux}}^{\mathrm{T}} & \boldsymbol{W}_{\mathrm{u}} \end{bmatrix} > 0$$
(75)

such that

$$\int_{0}^{\infty} [\mathbf{x}^{\mathrm{T}} \mathbf{u}^{\mathrm{T}}] \begin{bmatrix} \mathbf{W}_{\mathrm{x}} & \mathbf{W}_{\mathrm{ux}} \\ \mathbf{W}_{\mathrm{ux}}^{\mathrm{T}} & \mathbf{W}_{\mathrm{u}} \end{bmatrix} \begin{bmatrix} \mathbf{x} \\ \mathbf{u} \end{bmatrix} \mathrm{d}t \to \min_{\mathbf{K} \in \mathbf{K}_{\mathbf{S}}} \mathrm{tab}$$
(76)

if

$$\left\|\boldsymbol{W}_{u}\right\| > \frac{\left\|\boldsymbol{B}^{\mathrm{T}}\boldsymbol{P}\right\|}{2\left\|\boldsymbol{P}(\boldsymbol{A}+\boldsymbol{B}\boldsymbol{K})\right\|}$$
(77)

where
$$\boldsymbol{P} = \boldsymbol{P}^{\mathrm{T}} > 0$$
 satisfies the Lyapunov equation
 $\boldsymbol{P}(\boldsymbol{A} + \boldsymbol{B}\boldsymbol{K}) + (\boldsymbol{A} + \boldsymbol{B}\boldsymbol{K})^{\mathrm{T}} \boldsymbol{P} < 0$ (78)

Then

$$W_{\rm x} = -\boldsymbol{P}(\boldsymbol{A} + \boldsymbol{B}\boldsymbol{K}) - (\boldsymbol{A} + \boldsymbol{B}\boldsymbol{K})^{\rm T}\boldsymbol{P} + \boldsymbol{K}^{\rm T}\boldsymbol{W}_{\rm u}\boldsymbol{K} + \boldsymbol{K}^{\rm T}\boldsymbol{B}^{\rm T}\boldsymbol{P} + \boldsymbol{P}\boldsymbol{B}\boldsymbol{K}$$
(79)

$$\boldsymbol{W}_{\rm ux} = -(\boldsymbol{B}^{\rm T} \boldsymbol{P} + \boldsymbol{W}_{\rm u} \boldsymbol{K}) \tag{80}$$

Example 4

Consider the *Example 3* again. Let

 $\dot{x} = -2x + u$

and apply the state feedback k=1. The closed loop system $\dot{\bar{x}} = -1\bar{x} + u$ becomes stable and "slower". It can be shown that this k=1 is optimal for the *LQR* performance index

$$\int_{0}^{\infty} (5x^{2} - 4xu + u^{2}) dt$$
(81)

Indeed, using the Riccati-equation with

$$A = A = a = -2 \qquad B = B = b = 1 \qquad W_{x} = W_{x} = w_{x} = 5$$
$$W_{ux} = W_{ux} = w_{ux} = -2 \qquad W_{u} = W_{u} = w_{u} = 1$$

and

$$-4p^2 - (p-2)^2 + 5 = 0$$

and choosing the positive solution p = 1, the state feedback is given by

$$k = -w_{u}^{-1}(bp + w_{ux}) = -(1-2) = 1$$

and the closed loop matrix $\overline{A} = \overline{A} = \overline{a} = a + bk = -2 + 1 = -1$ as required, i.e., $p_1 = -r_1 = -1$. So the closed-loop is slower-

This result was obtained by using the method in Proposition 4. Pick any p > 0 such that it is a solution of the Lyapunov equation 2p(a+bk) < 0. Since $\bar{a} = a+bk = -1$ and 2p(-1) < 0 for all p > 0, one can choose p = 1 and compute

$$w_{\rm u,min} = \frac{(bp)^2}{2p|\overline{a}|} = \frac{1}{2}$$

Choose any $w_u > w_{u,\min}$, e.g., let $w_u = 1$, then $w_x = 2 + 1 + 2 = 5$ and $w_{ux} = -(1+1) = -2$. Notice that this solution is not unique, any $W_u = w_u \ge 1$ would do, e.g., $w_u = 2$ results in $w_x = 10$, $w_{ux} = -4$.

7. Conclusions

The paper presents the specific historical comparison of the relationships between the classical quadratic integral criterion, the pole-placement state feedback, the algebraic Riccati equation based LQR paradigm and Kalman's frequency domain approach.

Then two low order examples are shown how the obtained quadratic polynomial equation can be used. It is shown that arbitrary pole placement is not possible by standard classical LQ optimality by choosing only W_x , W_u weights. For a second order case the unreachable domains are graphically demonstrated.

The *MIMO LTI* case is discussed next with more general *LQR* criterion which penalizes the interaction between the state and input variables. In this framework it is possible to obtain *LQR* solutions for the whole parameter space, but the design of the crossterm weight W_{ux} is necessary, too. The uniqueness of the proposed solution is not guaranteed.

Acknowledgement

This work was supported in part by the Control Engineering Research Group of the HAS, at the Budapest University of Technology and Economics and by the project TAMOP 4.2.2.A-11/1/KONV-2012-2012, at the Széchenyi University of Győr.

References

- [1] Rekasius, Z.V.: A general performance index for analytica of control systems, *IRE Transactions on Automatic Control*, p. 217, 1960
- [2] Feldbaum, A.A.: *Theoretical foundations of automatic systems* (in Russian), State Publishing House in Physics and Mathematics, Moscow, 1960
- [3] Csáki, F.: State-space methods for control systems, Akadémiai Kiadó, Budapest, 1978
- [4] Kailath, T.: *Linear systems*, Prentice Hall, 1980
- [5] Grimble, M.J., Kucera, V.: Polynomial methods for control systems design, Springer, Berlin, 1996
- [6] Åström, K.J.: *Control system design*, Lecture Notes, University of California, Santa Barbara, 2002
- [7] Bányász, Cs., Keviczky, L.: *State-feedback solutions via transfer function representations*, Journal of Systems Science, vol. 30, no. 2, pp. 21-34, 2004
- [8] Keviczky, L., Bányász, Cs.: Model error properties of observer-based statefeedback controller, 6. Int. Conf. System identification and control problems SICPRO'07, Moscow, Russia, pp. 879-888, 2007
- [9] Anderson, B.D.O., Moore, J.B.: *Optimal control, Linear Quadratic Methods,* Prentice-Hall, 1989
- [10] Casti, J.: The linear-quadratic control problem: some recent results and outstanding problems, SIAM Review, vol. 22, no. 4, pp. 459-485, 1980

- [11] Cigler, J., Kucera, V.: *Pole-by-Pole shifting via a linear-quadratic regulation*, 17th Int. Conf. on Process Control, Strbske Pleso, Slovakia, pp. 1-9, 2009
- [12] Gattami, A., Rantzer, A.: Linear quadratic performance criteria for cascade control, Conf. on Decision and Control and European Control Conference CDC-ECC'05, pp. 3632-3637, 2005
- [13] Jameson, A.: Inverse problem of linear optimal control, SIAM Journal on Control. vol. 11, no. 1, pp. 1-19, 1973
- [14] Medanic, J., Tharp, H.S., Perkins, W.R.: Pole placement by performance criterion modification, IEEE Trans. on Aut. Control, vol. 33, no. 5, pp. 469-472, 1988
- [15] Mehdi, D., Hamid, Al M., Perrin, F.: Robustness and optimality of linear quadratic controller for uncertain systems, Automatica, vol. 32, no. 7, pp. 1081-1083, 1996
- [16] Molinari, B.: The stable regulator problem and its inverse, IEEE Trans. on Aut. Control, vol. 18, no. 5, pp. 454-459, 1973
- [17] Willems, J.: Least squares stationary optimal control and the algebraic Riccati equation, IEEE Trans. on Aut. Control, vol. 16, no. 6, pp. 621-634, 2003
- [18] Yao, D., Zhang, S., Zhou, X.: LQ control via semi-definite programming, 38th IEEE Conference on Decision and Control CDC99, pp. 1027-1032, 1999
- [19] Sugimoto, K.: Partial pole placement by LQ regulators: an inverse problem approach, IEEE Trans. on Aut. Control, vol. 43, no. 5, pp. 706-708, 1998
- [20] Alexandridis, A.T., Galanos, G.D.: Optimal pole-placement for linear multi-input controllable systems, IEEE Trans. Circuits Syst., vol. CAS-34, pp. 1602-1604, 1987
- [21] Alexandridis, A.T.: Algorithm for the design of state feedback controllers by optimal eigenstructure assignment, Proc. ECC European Control Conference, vol. 4b, pp. 3365-3369, 1995
- [22] Iracleous, D.P., Alexandridis, A.T.: A simple solution to the optimal eigenvalue assignment problem, IEEE Trans. on Aut. Control, vol. 44, no. 10, pp. 1746–1749, 1999